


TIPS, TOOLS AND TECHNIQUES - 2023



Renewable Energy Education for a Sustainable Future





Remove spark
plug - add 4 to 5
drops of gas in
cylinder. Replace
spark plug and
spark plug wire
and start generator






Use a piece of conduit to assist pulling wire connected to wire gutter

Mark reels large and small to track wire colors


circuits



"Solaredge" inverter requires 8 clear modules to start









SOLAR ENERGY INTERNATIONAL



Air intake through open windows



Building with large exhaust vent for air cooled generator – deep snow conditions

Cordless Palm Hammer



Use stainless steel scouring pad to plug conduit ends for rodent control







Plugging unused holes in electrical boxes is a **NEC** code requirement NEC 110.12(A)










Many larger diameter wires have printed lengths every foot


















Flexible – adjustable battery cables



SULAR ENERGY INTERNATIONAL

Some 10 to 30 amp breakers rated for two wires






Terminations

The 10–30 A circuit breakers have pressure plate terminals suitable for single or two-wire terminations. Copper or aluminum conductors may be used as outlined in Table 2. QO-GFI 15–30 A and QO-AFI circuit breakers have pressure plate terminals suitable for single-wire terminations. These circuit breakers are suitable for use with 60°C or 75°C conductors.

The QO 35–200 A and all QO-PL and QOT tandem circuit breakers have box-type lugs suitable for single-wire terminations. These circuit breakers are suitable for use with 75°C conductors.

Table 2: Terminations


Circuit Breaker Types	Rating	Wire Size	
	10-30 A	(1) 14-8 AWG (1.5-3.3 mm ²) Al/Cu (2) 14-10 AWG (1.5-2.6 mm ²) Cu	
QO, QOB, QO-VH, QOB-VH	35-70 A	(1) 8-2 AWG (3.3-6.5 mm ²) Al/Cu	





of a rope around the object and take a turn around the standing part. Tuck the working end back around itself 3 times with the lay of the rope.

Timber Hitch used to pull wire through conduit. Wrap "Mule tape with duct tape or wrapping tape after tying knot











"Pitch Hopper"
















"winch needed to remove wire from "Liquidtight"

"Mitrex" Solar Modules






242-02173, 242-02174



NOTE: CAN BE DECK-MOUNTED OR RAFTER-MOUNTED	PARTS LIST				
	ITEM	QTY	DESCRIPTION		
	1	1	BOLT, FLANGE, SERRATED, 5/16IN-18 X 1-3/4IN, SS		
	2	1	SNAPNRACK, RL UNIVERSAL, MOUNT SPRING, SS		
	3	1	SNAPNRACK, SPEEDSEAL DECKFOOT BASE, SEALING, SILVER / BLACK		
	4	1	SNAPNRACK, ULTRA RAIL MOUNT THRU PRC, CLEAR		
	5	1	SNAPNRACK, ULTRA RAIL MOUNT TAPPED PRC, CLEAR		
MATERIALS:	DIE CAST A380 ALUMINUM, 6000 SERIES ALUMINUM, STAINLESS STEEL, FOAM				
DESIGN LOAD (LBS):	SEE STRUCTURAL ENGINEERING OPTIONS:				
JLTIMATE LOAD (LBS):	SEE STRUCTURAL ENGINEERING SILVER / BLACK				
TORQUE SPECIFICATION:	12 LB-FT				
CERTIFICATION:	UL 2703, FILE E359313; WIND-DRIVEN RAIN TEST FROM SUBJECT UL 2582				
WEIGHT (LBS):	0.65				












"Milwaukee"
Air-Tip hose
attachments
for vacuuming
string in
conduit






"Itool" wire tugger









with foot pedal control



Mark depth of hole with black marker








Switch cover with one side access only

2021 NFPA 70E Part 11, 205.2

A single-line diagram, where provided for electrical system, shall be maintained in a legible condition and shall be kept current

Laminate and place on inside of panel cover










Battery box heater

Catalytic heater for lithium-ion batteries








"Mud mixer" portable mixer







1 CY per hour -\$ 3,000




"DEP XTREME" Suction cup module lift



Use PVC roller to remove modules



PVC pipe used to roll off solar modules





solar

Conduit stand off support







String reel uptake









RELIANCE CONTROLS® PRO/TRAN 2® PORTABLE GENERATOR TRANSFER SWITCH, 125V, 30A, NEMA L14-30, 4 CIRCUITS, METAL, GRAY - #304A1

304A1


FEATURES

- Completely pre-wired for easy installation
- Eliminates the dangers associated with back-feeding
- Cover included to protect toggle switches and circuit breakers
- Metal cabinet, designed for indoor use
- Includes color-coded wattmeters and an L14-30 power inlet
- cULus 1008 Listed





Use a screwdriver to pre-bend wires in a junction box








Metal roof penetration device for campers



How to drill larger hole





RMS graphical calculation




$$V_{\text{TRMS}} = \sqrt{\frac{V_1^2 + V_2^2 + ... + V_n^2}{n}}$$

Calculation of RMS voltage by Graphical method







power'



© Copyright 2012



2020 NEC 250.94(A) Bonding of communication systems

An intersystem bonding termination (IBT) for connecting intersystem bonding conductors shall be provided external to enclosures at the service equipment or metering equipment enclosure and at the disconnecting means for any additional buildings or structures.

